

ATTACHMENT 14

Sewage evaporation pond influent; nutrients and coliform organisms analytical results from samples collected at sampling location ISWP.

Parameter	Units	ISWP	Coliform resample^a
Nutrients		9/20/04	11/17/04
Ammonia nitrogen (as N)	mg/L	33	
Nitrite (as N)	mg/L	< 0.5	
Nitrite (as NO ₂)	mg/L	< 0.5	
Total Kjeldahl nitrogen	mg/L	69	
Coliform organisms			
Fecal coliform	MPN/100 mL	> 1,600	2,200,000
Total coliform	MPN/100 mL	> 1,600	16,000,000

^aColiform organisms resampled to use a higher maximum limit of detection more appropriate for sewage.