

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

MONITORING AND REPORTING PROGRAM NO. 00-132  
FOR  
UNITED STATES DEPARTMENT OF INTERIOR,  
BUREAU OF INDIAN AFFAIRS, COLORADO RIVER AGENCY, TRUSTEE  
FOR  
COLORADO RIVER INDIAN TRIBES  
RIVER PROPERTIES, OPERATOR  
RIVER REFLECTIONS MOBILE HOME PARK  
Northeast of Earp - San Bernardino County

Location of Discharge: SW 1/4 NE 1/4 of Section 10, T1N, R26E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Estimate of maximum daily flow (GPD) of sewage discharged to basin(s).
2. Number of mobile homes and restrooms presently connected to the sewerage system.
3. List any proposed changes in the sewage disposal facilities during the upcoming year.
4. Explain any problems in the sewage treatment and disposal system during the preceding year.
5. Report the Total Dissolved Solids concentration(s) of the water supply well(s) nearest to the facility.
6. The oxidation/infiltration basin shall be sampled (if wastewater is contained therein) quarterly during March, June, September and December, and annually during November each year. The samples shall be analyzed for the following:

<u>Constituent</u>	<u>Unit</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Total Dissolved Solids	mg/L <sup>1</sup>	Grab	Quarterly
Volatile Organics	µg/L <sup>2</sup>	Grab	Quarterly
Nitrate as NO <sub>3</sub> -N	mg/L	Grab	Quarterly
Total Nitrogen	mg/L	Grab	Quarterly

REPORTING

---

<sup>1</sup> mg/L - milligrams-per-Liter

<sup>2</sup> µg/L - microgram-per-Liter

1. Immediately report to this office by telephone and follow-up by letter any failure in the sewerage system.
2. Monitoring reports shall be submitted to the Regional Board by January 15 of each year.
3. Submit monitoring reports to:

California Regional Water Quality Control Board  
Colorado River Basin Region  
73-720 Fred Waring, Suite 100  
Palm Desert, CA 92260

Ordered by: original signed by/  
Executive Officer

November 8, 2000  
Date